

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers**Service History**

Order # 11380

JOB LOCATION

East Park Retirement
6360 Elmdale Rd
Brook Park Ohio 44142
216-267-7067
Service Date: 10/28/2015

P1: (216)267-7067
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

CONTACT

Dave

TECHNICIAN

JAL

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 PX-155701	Sprinkler Room 2774	5 ABC	1998	2010		PX-155701	10/28/2015 8:57:03 AM
2 JV-00039285	Kitchen store rm	10 ABC	2000	2013		AQ0004620	10/28/2015 9:05:31 AM
3 VK571479	Kitchen exit	10 ABC	2002	2014		VK571479	10/28/2015 9:02:02 AM
4 AC87412	:Kitchen	6 Liter Class K	2010	2015*		AC87412	11/6/2015 12:52:20 PM
5 A27520174	Laundry	10 ABC	2014			A27520174	10/28/2015 9:00:41 AM
6 RH-025697	Dining 2780	5 ABC	1999	2010		RH-025697	10/28/2015 8:59:25 AM
7 RH-025704	dinning 2770	5 ABC	1999	2011		RH-025704	10/28/2015 8:58:08 AM
8 RG-999895	business office 2779	5 ABC	1999	2011		RG-999895	10/28/2015 8:54:58 AM
9 A31463187	:Exit to courtyard	5 ABC	2014			A31463187	10/28/2015 8:53:34 AM
10 CC09713	By 502 2764	5 ABC	2013			CC09713	10/28/2015 8:51:53 AM
11 RC-584634	By 605 2763	5 ABC	1999	2011		RC-584634	10/28/2015 8:44:29 AM
12 XA681625	By 805 2762	5 ABC	2005		2011	XA681625	10/28/2015 8:47:34 AM
13 YG632251	By 801 2773	5 ABC	2006		2012	YG632251	10/28/2015 8:46:24 AM
14 RH-025760	102 2775	5 ABC	1999	2010		RH-025760	10/28/2015 8:41:21 AM
15 RX-207572	By 110 2769	5 ABC	2000	2011		RX-207572	10/28/2015 8:31:11 AM
16 ZX27558	By N store rm 2766	5 ABC	2008		2014	ZX27558	10/28/2015 8:38:24 AM
17 A34490549	By 702 2767	5 ABC	2014	2014		A34490549	10/28/2015 8:37:10 AM
18 LW-742785	By 705 2768	5 ABC	1993	2005	2011	LW-742785	10/28/2015 8:35:37 AM
19 BZ311710	By 411 2765	5 ABC	2013			BZ311710	10/28/2015 8:33:56 AM
20 RG-999923	By 403 2761	5 ABC	1999	2011		RG-999923	10/28/2015 8:32:40 AM
21 A902249	Maintl shop	10 ABC	2009		2014	A902249	10/28/2015 10:15:57 AM
22 A31463084	by 308	5 ABC	2014			A31463084	10/28/2015 8:42:55 AM
23 XS277800	Exit By 301 2771	5 ABC	2006		2012	XS277800	10/28/2015 8:29:47 AM
24 RH-025693	By 207 2772	5 ABC	1999	2010		RH-025693	10/28/2015 8:28:53 AM
25 RC-602039	By 502 2760	5 ABC	1999	2011		RC-602039	10/28/2015 8:27:06 AM
26 A34490557	Ranch 4	5 ABC	2014			A34490557	10/28/2015 10:50:33 AM
27 RK-047234	Ranch 4 2790	5 ABC	1999	2011		RK-047234	10/28/2015 10:49:07 AM
28 RH-025649	Ranch 3 2791	5 ABC	1999	2011		RH-025649	10/28/2015 10:44:42 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers**Service History**

Order # 11380

JOB LOCATION

East Park Retirement
6360 Elmdale Rd
Brook Park Ohio 44142
216-267-7067

P1: (216)267-7067

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
29 RH-025715	Ranch 3 2792	5 ABC	1999	2011		RH-025715	10/28/2015 10:47:13 AM
30 RH-025689	Ranch 2 2793	5 ABC	1999	2011		RH-025689	10/28/2015 10:40:25 AM
31 RH-025719	Ranch 2 2794	5 ABC	1999	2011		RH-025719	10/28/2015 10:34:07 AM
32 RH-025667	Ranch 1 2795	5 ABC	1999	2011		RH-025667	10/28/2015 10:29:34 AM
33 RH-025733	Ranch 1 2796	5 ABC	1999	2013		RH-025733	10/28/2015 10:28:32 AM

Extinguisher Work Summary as of 10/28/2015

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	0	0	31	0	1	0	0	0	32
Class K	1	0	0	0	0	0	0	0	1
Totals	1	0	31	0	1	0	0	0	33

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 11/24/2015 10:14:30 AM

2/2