

**Fire Loss Control, Inc.**590 Pearl Road  
Brunswick, Ohio 44212**Fire Extinguishers****Service History**

Order # 11390

**JOB LOCATION**Erievue Plaza c/o Ohio Realty  
65-75 Erievue Plaza  
Cleveland Ohio 44114  
330-840-4365 (cell phone)  
Service Date: 10/29/2015P1: (330)840-4365  
P2:  
F:**CLIENT**Fire Loss Control, Inc.  
590 Pearl Road  
Brunswick Ohio 44212**CONTACT**

Ernie Zaylcek

**TECHNICIAN**

JAL

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 RP-664234	1:6301 Maint. by Door	10 ABC	2000	2012		AQ0007226	10/29/2015 10:47:38 AM
2 PJ-362459	1:6304 75 City Stat Office	10 ABC	1997	2009	2015*	PJ-362459	10/29/2015 9:54:46 AM
3 BX234205	1:Maint spare	5 ABC	2013			BX234205	10/29/2015 9:58:36 AM
4 RP-666407	1:6306 65 Air Quality Monitor	10 ABC	2000	2012		AQ0007235	10/29/2015 10:42:50 AM
5 PR-174922	1:6360 75 MRI Network	10 ABC	1998	2010		PR-174922	10/29/2015 10:45:26 AM
6 PJ-413348	1:6362 75 MRI Network	5 ABC	1997	2009	2015*	PJ-413348	10/29/2015 9:40:22 AM
7 RP-666835	1:6363 65 Lobby	5 ABC	2000	2012		AQ0007234	10/29/2015 9:55:58 AM
8 RP-666836	1:6370 65 Corridor	10 ABC	2000	2012		AQ0007233	10/29/2015 9:53:27 AM
9 BM658656	1:Management office	5 ABC	2013			BM658656	10/29/2015 9:58:13 AM
10 CC09705	1:Management office	5 ABC	2013			CC09705	10/29/2015 9:59:05 AM
11 WG981399	1:Broadvox WH	5 ABC	2004		2010	WG981399	10/29/2015 9:59:38 AM
12 WG985368	1:Broadvox WH	5 ABC	2004		2010	WG985368	10/29/2015 10:00:10 AM
13 SP-824402	2:6307 Bldg 75 Elev.Lobby	5 ABC	2001	2012		SP-824402	10/29/2015 10:38:07 AM
14 LW-685409	2:6308 Bldg 75 Kitchen	5 ABC	1993	2011		LW-685409	10/29/2015 10:38:23 AM
15 PJ-362484	2:6309 Bldg 75 Cleve. Air	10 ABC	1997	2009	2015*	PJ-362484	10/29/2015 9:48:05 AM
16 B01574811	2:Bldg 65 by Elev. Lobby	10 ABC	2015			B01574811	10/29/2015 10:29:35 AM
17 RP470190	2:6311 Bldg 65 Rm 203	5 ABC	2000	2012		AQ0007263	10/29/2015 10:30:13 AM
18 B02530938	2:Bldg 65 S	10 ABC	2015			B02530938	10/29/2015 10:32:45 AM
19 RK-469547	2:6313 Bldg 65 copy rm	5 ABC	2000	2012		AQ0007262	10/29/2015 10:33:24 AM
20 TB154106	2:6314 Bldg 75 Cleve. Air	5 ABC	2002	2014		TB154106	10/29/2015 10:35:05 AM
21 BM659648	2:75 SE coffee station	5 ABC	2013			BM659648	10/29/2015 10:36:15 AM
22 CC09709	2:75 SE	5 ABC	2013			CC09709	10/29/2015 10:37:17 AM
23 PJ-413342	3:6315 Bldg 75 City of Cle	5 ABC	1997	2009	2015*	PJ-413342	10/29/2015 9:41:08 AM
24 PJ-413320	3:6316 Bldg 75 City of Clev	5 ABC	1997	2009	2015*	PJ-413320	10/29/2015 9:42:12 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Fire Loss Control, Inc.**590 Pearl Road  
Brunswick, Ohio 44212**Fire Extinguishers****Service History**

Order # 11390

**JOB LOCATION**Erievue Plaza c/o Ohio Realty  
65-75 Erievue Plaza  
Cleveland Ohio 44114  
330-840-4365 (cell phone)P1: (330)840-4365  
P2:  
F:**CLIENT**Fire Loss Control, Inc.  
590 Pearl Road  
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
25 A98118289	3:Bldg 75 City of Cleve.	5 ABC	2015			A98118289	10/29/2015 10:26:10 AM
26 YB368240	3:6318 Bldg 65 City of Cleve	5 ABC	2006		2012	YB368240	10/29/2015 10:26:34 AM
27 PH-904114	3:6319 Bldg 65 Elev. Lobby	10 ABC	1997	2009	2015*	PH-904114	10/29/2015 10:18:33 AM
28 PJ-413301	3:6320 Bldg 65 W	5 ABC	1997	2007	2013	PJ-413301	10/29/2015 10:19:26 AM
29 PJ-413360	3:6321 Bldg 65 SW	5 ABC	1997	2009	2015*	PJ-413360	10/29/2015 9:44:27 AM
30 A98118794	3:Bldg 65 S	5 ABC	2015			A98118794	10/29/2015 10:22:46 AM
31 PJ-413349	3:6323 Bldg 75 SE	5 ABC	1997	2009	2015*	PJ-413349	10/29/2015 9:43:39 AM
32 RP-664224	4:6324 Bldg 75 Broadvox	10 ABC	2000	2012		AQ0007255	10/29/2015 9:19:52 AM
33 TB792660	4:6325 Broadvox Bldg 75	10 ABC	2002	2013		TB792660	10/29/2015 9:21:19 AM
34 BM657524	4:75 Broadvox break rm	5 ABC	2013			BM657524	10/29/2015 9:22:36 AM
35 RP-667238	4:6326 Braodvox Bldg 65	10 ABC	2000	2012		AQ0007258	10/29/2015 9:15:28 AM
36 RP-666840	4:6327 Broadvox Kitchen	10 ABC	2000	2012		AQ0007256	10/29/2015 9:24:15 AM
37 RP-038869	4:6328 Elevator Bldg 65	10 ABC	2000	2012		RP-038869	10/29/2015 9:12:39 AM
38 RP-664222	4:6329 Broadvox Bldg 75 N	10 ABC	2000	2012		AQ0007254	10/29/2015 9:26:02 AM
39 RP-666837	4:6330 Bldg 65 S	10 ABC	2000	2012		AQ0007259	10/29/2015 9:16:53 AM
40 RP-667231	4:6331 Bldg 65 NW Braodvox	10 ABC	2000	2012		AQ0007257	10/29/2015 9:13:57 AM
41 A98117843	5:Bldg 75 N	5 ABC	2015			A98117843	10/29/2015 9:08:08 AM
42 PH-904103	5:6305 Front Lobby Bldg 75 6305	10 ABC	1997	2009	2015*	PH-904103	10/29/2015 9:49:30 AM
43 AX82746	5:2147 Bldg 75 NE	5 ABC	2012			AX82746	10/29/2015 9:02:04 AM
44 B04996799	5:Bldg 75 SW	5 ABC	2015			B04996799	10/29/2015 8:56:59 AM
45 B04995040	5:Bldg 75 SE	5 ABC	2015			B04995040	10/29/2015 9:01:05 AM
46 B04996796	5:65 So	5 ABC	2015			B04996796	10/29/2015 8:54:00 AM
47 SM996172	5:6336 65 Elevator Lobby	10 ABC	2001	2013		SM996172	10/29/2015 8:49:05 AM
48 CC09707	5:65 NE	5 ABC	2013			CC09707	10/29/2015 9:10:19 AM
49 RK-469551	5:6337 Bldg 75 NW	5 ABC	2000	2012		AQ0007252	10/29/2015 9:04:07 AM
50 VR-738566	5:6338 Bldg 65 N	5 ABC	2000	2014		AQ0008774	10/29/2015 8:51:12 AM
51 PJ-362464	6:6302 Bldg 75 N	10 ABC	1997	2009	2015*	PJ-362464	10/29/2015 9:46:57 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Fire Loss Control, Inc.**590 Pearl Road  
Brunswick, Ohio 44212**Fire Extinguishers****Service History**

Order # 11390

**JOB LOCATION**Erievue Plaza c/o Ohio Realty  
65-75 Erievue Plaza  
Cleveland Ohio 44114  
330-840-4365 (cell phone)P1: (330)840-4365  
P2:  
F:**CLIENT**Fire Loss Control, Inc.  
590 Pearl Road  
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
52 PJ-362465	6:6303 Bldg 75 NE	10 ABC	1997	2009	2015*	PJ-362465	10/29/2015 9:46:34 AM
53 AX83401	6:2146 Bldg 65 S	5 ABC	2012			AX83401	10/29/2015 10:14:16 AM
54 RP-038896	6:6339 Bldg 65 Elev. Lobby	10 ABC	2000	2012		RP-038896	10/29/2015 10:13:51 AM
55 RP-664232	8:6342 75 Penthouse	10 ABC	2000	2012		AQ0007227	10/29/2015 10:10:32 AM
56 RP-667194	8:6343 75 Elev. Rm	10 ABC	2000	2012		AQ0007228	10/29/2015 10:08:48 AM
57 RP-038870	8:6345 65 Rooftop PH	10 ABC	2000	2012		RP-038870	10/29/2015 10:06:57 AM
58 PD-035029	8:2148 65 Penthouse	10 ABC	1997	2009	2015*	PD-035029	10/29/2015 10:05:04 AM
59 PH-904117	8:6346 65 Elevator Rm Rooftop 6346	10 ABC	1997	2009	2015*	PH-904117	10/29/2015 10:05:18 AM
60 PH-904118	8:6347 Bldg 65 Elevator Rm Rtt 6347	10 ABC	1997	2009	2015*	PH-904118	10/29/2015 10:05:36 AM
61 B04994103	7:Bldg 65 SE	5 ABC	2015			B04994103	10/29/2015 8:25:19 AM
62 B04995042	7:Bldg 65 NE	5 ABC	2015			B04995042	10/29/2015 8:21:45 AM
63 A98117855	7:Bldg 65 S E	5 ABC	2015			A98117855	10/29/2015 8:16:57 AM
64 B04994104	7:Bldg 65 N W	5 ABC	2015			B04994104	10/29/2015 8:41:37 AM
65 RP-666530	7:6348 65 Elevator Lobby	10 ABC	2000	2012		AQ0007229	10/29/2015 8:13:00 AM
66 PJ-413344	7:6340 Bldg 75 by Elev.	5 ABC	1997	2009	2015*	PJ-413344	10/29/2015 9:42:58 AM
67 B04995652	7:Bld 75 S	5 ABC	2015			B04995652	10/29/2015 8:27:32 AM
68 A98118800	7:Bldg 75 E	5 ABC	2015			A98118800	10/29/2015 8:33:05 AM
69 B04995655	7:Bldg 75 SE	5 ABC	2015			B04995655	10/29/2015 8:30:10 AM
70 B04995653	7:Bldg 75 NW	5 ABC	2015			B04995653	10/29/2015 8:36:49 AM
71 RP-664226	Basement :6355 75 Mech. Rm	10 ABC	2000	2012		AQ0007236	10/29/2015 11:11:24 AM
72 RP-666819	Basement :6356 75 Mech. Rm	10 ABC	2000	2012		AQ0007239	10/29/2015 11:17:21 AM
73 RP-666832	Basement :6357 75 Mech. Rm	10 ABC	2000	2012		AQ0007237	10/29/2015 11:14:43 AM
74 RP-666838	Basement :6358 75 Mech. Rm	10 ABC	2000	2012		AQ0007238	10/29/2015 11:16:00 AM
75 PJ-413347	Basement :6359 Storeroom	5 ABC	1997	2011		PJ-413347	10/29/2015 11:09:27 AM
76 AX79950	Basement :2150 65 Elev. Pit	5 ABC	2012			AX79950	10/29/2015 11:02:20 AM
77 AX79951	Basement :2149 75 Elev. dit	5 ABC	2012			AX79951	10/29/2015 11:19:47 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Fire Loss Control, Inc.**590 Pearl Road  
Brunswick, Ohio 44212**Fire Extinguishers****Service History**

Order # 11390

**JOB LOCATION**Erievue Plaza c/o Ohio Realty  
65-75 Erievue Plaza  
Cleveland Ohio 44114  
330-840-4365 (cell phone)P1: (330)840-4365  
P2:  
F:**CLIENT**Fire Loss Control, Inc.  
590 Pearl Road  
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
78 RP-664235	Basement :6364 65 Corridor	10 ABC	2000	2012		AQ0007232	10/29/2015 11:06:10 AM
79 PJ-362486	Basement :6365 65 Elevator Rm	10 ABC	1997	2009	2015*	PJ-362486	10/29/2015 11:05:48 AM
80 V-0861140	Basement :6366 Phone Room	10 FE36	1999	2011		V-0861140	10/29/2015 11:28:28 AM
81 RP-666820	Basement :6367 Hall by Rm 1	10 ABC	2000	2012		AQ0007230	10/29/2015 11:01:59 AM
82 RP-666532	Basement :6368 Mech. Riser Rm	10 ABC	2000	2012		AQ0007231	10/29/2015 11:03:21 AM
83 SG-502584	8:6344 65 Rooftop PH	10 ABC	2001	2013		SG-502584	*** Missing ***

## Extinguisher Work Summary as of 10/29/2015

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	0	16	49	0	0	16	0	1	82
FE36	0	0	1	0	0	0	0	0	1
Totals	0	16	50	0	0	16	0	1	83

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS