

**Fire Loss Control, Inc.**

590 Pearl Road  
Brunswick, Ohio 44212

**Fire Extinguishers****Service History**

Order # 11605

**JOB LOCATION**

Michael White Building  
3750 Flemming Avnue  
Cleveland Ohio 44115  
216-658-7638

P1: (216)658-7638

P2:

F:

**CLIENT**

Fire Loss Control, Inc.  
590 Pearl Road  
Brunswick Ohio 44212

**CONTACT**

Melinda Matlock

**TECHNICIAN**

JAL

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 WR625891	4:Hall	10 ABC	2004		2010	WR625891	11/11/2015 11:13:22 AM
2 TB-612865	4:Hall	10 ABC	2003	2015*		TB-612865	11/11/2015 2:06:03 PM
3 SX-173365	4:Lobby	10 ABC	2002	2015*		SX-173365	11/11/2015 2:04:47 PM
4 VY-365252	3:Hall	10 ABC	2003	2015*		VY-365252	11/11/2015 2:07:34 PM
5 VY-365254	3:Hall	10 ABC	2003	2015*		VY-365254	11/11/2015 2:08:19 PM
6 LW-00900295	3:Lobby	10 ABC	1993	2015*		AQ10032	11/11/2015 2:09:33 PM
7 VY-365261	2:Hall	10 ABC	2003	2015*		VY-365261	11/11/2015 2:10:51 PM
8 KF-00807916	2:Hall	10 ABC	1991	2015*		AQ10033	11/11/2015 2:12:12 PM
9 HW-00528764	2:Lobby	10 ABC	1998	2015*		AQ10034	11/11/2015 2:13:02 PM
10 RK-609022	1:Elevator rm	10 ABC	1999	2015*		RK-609022	11/11/2015 2:02:42 PM
11 SW565209	1:Trash rm	10 ABC	2002	2015*		SW565209	11/11/2015 2:01:13 PM
12 WR630882	1:North lobby entry	10 ABC	2004		2011	WR630882	11/11/2015 11:04:53 AM
13 WD271737	1:South lobby entry	10 ABC	2003	2015*		WD271737	11/11/2015 1:49:38 PM
14 XV-394689	1:Property manage office	10 ABC	2006		2013	AQ10029	11/11/2015 11:02:53 AM
15 XV-395010	1:South west entry	10 ABC	2006		2013	AQ10030	11/11/2015 11:08:21 AM
16 AC-759745	1:Day care kitchen	6 Liter Class K	2012			AC-759745	11/11/2015 11:25:34 AM
17 UN650413	1:Day care south exit	10 ABC	2003	2015*		AQ0005838	11/11/2015 1:54:08 PM
18 TF-193670	1:Day care east exit	10 ABC	2002	2015*		AQ10031	11/11/2015 1:53:09 PM

## Extinguisher Work Summary as of 11/11/2015

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	13	0	4	0	0	0	0	0	17
Class K	0	0	1	0	0	0	0	0	1
Totals	13	0	5	0	0	0	0	0	18

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS