

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11589

JOB LOCATION

Samaritan Care Center
806 E Washington Street
Medina Ohio 44256
330-725-4123

Service Date: 11/13/2015

CONTACT

Justin Pope

P1: (330)725-4123

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

TECHNICIAN

JAL

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Ansul

Model: R-102 3 Gallon

Location: Kitchen

Install Date: 1997

Last Service: 11/13/2015

Duct Size: 2-12 X 12

Plenum Size: 2-18 X 8

Serial #: R430685

Bar Code: AQ0007293

Timestamp:

Nozzle Type: 2W

Nozzle Type: 2-1N

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2008	☐
Monthly		☐
Recharge		☐
Semi-Annual	11/2015	☒
Flush Piping		☐
New		☐

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	3 Gal	Extinguishing Agent	2008	2008		N/A	AQ0008410	5/14/2014 9:21:15 AM

Replacement Parts

Qty	Description	Part No.	Replaced
3	Fuse Links 360°F K Link	360K-11	11/2015
7	Ansul Nozzle Cap	AS77695	11/2015

Appliances (Left to Right)

Num	Description	Size	Nozzle(s)
-----	-------------	------	-----------

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11589

JOB LOCATION

Samaritan Care Center
806 E Washington Street
Medina Ohio 44256
330-725-4123

P1: (330)725-4123

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num	Description	Size	Nozzle(s)
1	Range - 6 Burner		245, 1F
2	Grill - 24"		1N

INSPECTION**I. Fire Suppression Systems**

OK FAIL NA

1. Hood and appliances properly protected? ☒ ☐ ☐
2. Was nozzle/appliance alignment correct upon arrival? ☒ ☐ ☐
- If not was the alignment corrected during inspection?
3. System cylinder gauge in operable range? ☐ ☐ ☒
4. Cylinder weight or liquid level OK? ☒ ☐ ☐
5. Fusible links replaced? ☒ ☐ ☐
6. Actuation cartridge weight or gauge in operable range?
/* Stamped weight 43 1/8 oz, Actual weight 43 1/8 oz */ ☒ ☐ ☐
7. Complete fuel shut-down operational? ☒ ☐ ☐
8. Remote pull station accessible and operational? ☒ ☐ ☐
9. All components clean and free of grease? ☒ ☐ ☐
10. Nozzle caps cleaned or replaced? ☒ ☐ ☐
11. System meets manufacturer installation instructions? ☒ ☐ ☐
12. System conduit and piping securely mounted? ☒ ☐ ☐
13. Does system meet UL 300 standard? ☒ ☐ ☐
14. Employees trained in the proper operation of the system? ☒ ☐ ☐
15. Audible and/or visual alarms functional? ☒ ☐ ☐
16. System reset and placed back in service? ☒ ☐ ☐
17. System connected to central station? ☒ ☐ ☐
18. Class K extinguisher present and functional? ☒ ☐ ☐
19. Do hood and duct comply with NFPA #96? ☒ ☐ ☐
20. Company State of Ohio Certification # 53-28-1034 ☒ ☐ ☐
21. State of Ohio Certification Jon LeRoy 54-18-1535 ☒ ☐ ☐
22. State of Ohio Certification Randolph N Kaser 54-18-0381 ☐ ☐ ☒
23. Complete Hydrostatic Pressure Test Current ☒ ☐ ☐
24. Complete 6 Year Maintenance Current ☐ ☐ ☒

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection, Inc. / Fire Loss Control, Inc.

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11589

JOB LOCATION

Samaritan Care Center
806 E Washington Street
Medina Ohio 44256
330-725-4123

P1: (330)725-4123

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Technician

X 

Jonathan LeRoy

11/13/2015

Customer Signature

X _____

Fire Inspector

X _____

*** End Report: 1 ***

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS