

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers

Service History

Order # 11733

JOB LOCATION

Chardon Healthcare Center
620 Water Street
Chardon Ohio 44024
440-285-9400

Service Date: 12/8/2015

P1: (440)285-9400

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

CONTACT

Roger DeRubeis

TECHNICIAN

JAL

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 YR285612	Laundry	10 ABC	2007		2012	YR285612	12/8/2015 10:58:26 AM
2 A32968570	:Mechanical rm	10 ABC	2014			AQ10064	12/8/2015 10:59:13 AM
3 AB594839	Kitchen	6 Liter Class K	2007	2013		AB594839	12/8/2015 10:54:48 AM
4 BS896829	Dinning rm	5 ABC	2013			BS896829	12/8/2015 11:01:03 AM
5 BS899855	Hall at dinning	5 ABC	2013			BS899855	12/8/2015 11:03:38 AM
6 BX173469	Admin hall	10 ABC	2013			BX173469	12/8/2015 11:05:29 AM
7 YR284265	Front lobby	10 ABC	2007		2013	YR284265	12/8/2015 11:07:31 AM
8 BX169911	PT	10 ABC	2013			BX169911	12/8/2015 11:09:32 AM
9 X722439	Central supply	5 ABC	2010			X722439	12/8/2015 11:12:22 AM
10 YN866999	Linen rm	10 ABC	2007		2013	YN866999	12/8/2015 11:15:02 AM
11 BK146763	Mechanical rm 2	5 ABC	2012			BK146763	12/8/2015 11:17:19 AM
12 YK402591	Hall at rm 405	5 ABC	2007		2013	YK402591	12/8/2015 11:20:59 AM
13 YK404750	Hall at 302	5 ABC	2007		2013	YK404750	12/8/2015 11:23:45 AM
14 YS229641	Mechanical rm 3	10 ABC	2007		2014	YS229641	12/8/2015 11:26:28 AM
15 YK404753	100 Hall	5 ABC	2007		2013	YK404753	12/8/2015 11:28:50 AM
16 AP-855917	Pantry	10 ABC	2012			AP-855917	12/8/2015 11:31:09 AM
17 YK402998	200 Hall	5 ABC	2007		2013	YK402998	12/8/2015 11:34:01 AM
18 AL-256610	Bus	10 ABC	2011			AL-256610	12/8/2015 11:41:32 AM

Extinguisher Work Summary as of 12/8/2015

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	0	0	17	0	0	0	0	0	17
Class K	0	0	1	0	0	0	0	0	1
Totals	0	0	18	0	0	0	0	0	18

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS