

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11651

JOB LOCATION

Mentor Woods
8881 Schaefer Street
Mentor Ohio 44060
440-255-9309
Service Date: 12/3/2015

P1: (440)255-9309
P2:
F: (440)205-9120

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick. Oh 44212

CONTACT

Mark

TECHNICIAN

JAL

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Ansul

Model: R-102 6 Gallon

Location: Kitchen

Install Date: 1996

Last Service: 12/3/2015

Duct Size: 2 - 10" X 12"

Nozzle Type: 2 - 1W

Plenum Size: 2 - 18" X 10Ft

Nozzle Type: 2 - 1N

Serial #: R 362813

Bar Code: AQ0007317

Timestamp: 12/3/2015 3:00:24 PM

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2004	☐
Monthly		☐
Recharge		☐
Semi-Annual	12/2015	☒
Flush Piping		☐
New		☐

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	3 gal	Extinguishing Agent	2004	2004				
2	3 gal	Extinguishing Agent	1995	2007				

Replacement Parts

Qty	Description	Part No.	Replaced
4	Fuse Links 450°F K Link	450K-11	12/3/2015
10	Ansul Nozzle Cap	AS77695	12/2015

Appliances (Left to Right)

Num	Description	Size	Nozzle(s)
-----	-------------	------	-----------

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11651

JOB LOCATION

Mentor Woods
8881 Schaefer Street
Mentor Ohio 44060
440-255-9309

P1: (440)255-9309

P2:

F: (440)205-9120

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick. Oh 44212

Num	Description	Size	Nozzle(s)
1	Grill - 36"		1N
2	Range - 6 Burner		245, 1F
3	Tilt Skillet		

INSPECTION**I. Fire Suppression Systems**

OK FAIL NA

- | | | | |
|--|-------------------------------------|--------------------------|-------------------------------------|
| 1. Hood and appliances properly protected? | ☒ | ☐ | ☐ |
| 2. Was nozzle/appliance alignment correct upon arrival? | ☒ | ☐ | ☐ |
| If not was the alignment corrected during inspection? | | | |
| 3. System cylinder gauge in operable range? | ☐ | ☐ | ☒ |
| 4. Cylinder weight or liquid level OK? | ☒ | ☐ | ☐ |
| 5. Fusible links replaced? | ☒ | ☐ | ☐ |
| 6. Actuation cartridge weight or gauge in operable range? | ☒ | ☐ | ☐ |
| /* Stamped weight 107 7/8 oz, Actual weight 108 oz cartridge due for hydrostatic pressure testing or replacement */ | | | |
| 7. Complete fuel shut-down operational? | ☒ | ☐ | ☐ |
| 8. Remote pull station accessible and operational? | ☒ | ☐ | ☐ |
| 9. All components clean and free of grease? | ☒ | ☐ | ☐ |
| 10. Nozzle caps cleaned or replaced? | ☒ | ☐ | ☐ |
| 11. System meets manufacturer installation instructions? | ☒ | ☐ | ☐ |
| 12. System conduit and piping securely mounted? | ☒ | ☐ | ☐ |
| 13. Does system meet UL 300 standard? | ☒ | ☐ | ☐ |
| 14. Employees trained in the proper operation of the system? | ☒ | ☐ | ☐ |
| 15. Audible and/or visual alarms functional? | ☒ | ☐ | ☐ |
| 16. System reset and placed back in service? | ☒ | ☐ | ☐ |
| 17. System connected to central station? | ☒ | ☐ | ☐ |
| 18. Class K extinguisher present and functional? | ☒ | ☐ | ☐ |
| 19. Do hood and duct comply with NFPA #96? | ☒ | ☐ | ☐ |
| 20. Company State of Ohio Certification # 53-28-1034 | ☒ | ☐ | ☐ |
| 21. State of Ohio Certification Jon LeRoy 54-18-1535 | ☒ | ☐ | ☐ |
| 22. State of Ohio Certification Randolph N Kaser 54-18-0381 | ☐ | ☐ | ☒ |
| 23. Complete Hydrostatic Pressure Test Current | ☒ | ☐ | ☐ |
| /* System cylinders due for hydrostatic pressure testing in 2016. One is stainless steel second cylinder is mild steel and can not be tested and must be replaced */ | | | |
| 24. Complete 6 Year Maintenance Current | ☐ | ☐ | ☒ |

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11651

JOB LOCATION

Mentor Woods
8881 Schaefer Street
Mentor Ohio 44060
440-255-9309

P1: (440)255-9309

P2:

F: (440)205-9120

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick. Oh 44212

INSPECTION**I. Fire Suppression Systems**

OK FAIL NA

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection, Inc. / Fire Loss Control, Inc.

Technician

X 

Jonathan LeRoy

12/3/2015

Customer Signature

X _____

Fire Inspector

X _____

*** End Report: 1 ***

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS