

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44212**Fire Suppression Systems****Service History**

Order # 11889

JOB LOCATIONCandlewood Park Healthcare Center
1835 Belmore Road
East Cleveland Ohio 44112
216-268-3600

P1: (216)268-3600

P2:

F:

Service Date: 1/15/2016

CONTACT

Dean

CLIENTFire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212**TECHNICIAN**

JAL

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Kidde

Model: WHDR-450

Location: Kitchen

Install Date: 2003

Last Service: 1/2016

Duct Size: 10" x 22"

Nozzle Type: 2 ADP

Plenum Size: 18" x 11ft

Nozzle Type: 2 ADP

Serial #: TBA000587

Bar Code: AQ10028

Timestamp:

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2016	<input checked="" type="checkbox"/>
Monthly		<input type="checkbox"/>
Recharge	1/15/2016	<input checked="" type="checkbox"/>
Semi-Annual	11/2015	<input type="checkbox"/>
Flush Piping		<input type="checkbox"/>
New		<input type="checkbox"/>

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	4 gal	Extinguishing Agent	2003	2016		TBA000587		

Replacement Parts

Qty	Description	Part No.	Replaced
4	Fuse Links 450°F Globe ML	450ML-11	11/2015

Appliances (Left to Right)

Num	Description	Size	Nozzle(s)
1	Fryer - Gas		F, F

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems

Service History

Order # 11889

JOB LOCATION

Candlewood Park Healthcare Center
1835 Belmore Road
East Cleveland Ohio 44112
216-268-3600

P1: (216)268-3600
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num	Description	Size	Nozzle(s)
2	Range - 6 Burner		R, R
3	Grill - 24"		ADP, ADP

Fire Extinguisher Inspection

I. NFPA 10 6.2.2

OK FAIL NA

Periodic inspection of fire extinguishers shall include a check of at least the following items.

- 1. Located in designated place. OK FAIL NA
- 2. No obstructions to access or visibility. OK FAIL NA
- 3. Operating instructions on nameplate legible and facing outward. OK FAIL NA
- 4. Safety seals and tamper indicators not broken or missing. OK FAIL NA
- 5. Fullness determined by weighing or "hefting." OK FAIL NA
- 6. Examined for obvious physical damage, corrosion, leakage, or clogged nozzle. OK FAIL NA
- 7. Pressure gauge reading or indicator in the operable range or position. OK FAIL NA
- 8. HMIS label in place. OK FAIL NA

*** End Report: 1 ***

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS