

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44212**Fire Extinguishers****Service History**

Order # 11789

JOB LOCATIONColonial Manor Health Care
747 South Mount Vernon Avenue
Loudonville OH 44842P1: (419)994-4191
P2:
F: (419)994-3756**CLIENT**Fire Loss Control, Inc.
590 Pearl Road
Brunswick OH 44212

Service Date: 1/14/2016

CONTACT

Ed Gillette

TECHNICIAN

JAL

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 AA-780674	kitchen	6 Liter Class K	2004	2014		AA-780674	
2 WD576460	0302 kitchen	10 ABC	2004	*		WD576460	1/14/2016 7:49:02 AM
3 WD576467	0303 kitchen	10 ABC	2004	*		WD576467	1/14/2016 7:48:51 AM
4 WD576484	0304 kitchen	10 ABC	2004		2010	WD576484	1/14/2016 7:51:30 AM
5 A905800	:0305 laundry	10 ABC	2009		2015	A905800	1/14/2016 8:02:23 AM
6 A901788	:0306 hall by kitchen	10 ABC	2009		2015	A901788	1/14/2016 8:13:04 AM
7 MW-837364	0307 hall at 43	10 ABC	1995	2007	2013	MW-837364	1/14/2016 8:06:47 AM
8 KS-860963	0308 hall	10 ABC	1992		2011	AQ0007403	1/14/2016 8:03:17 AM
9 XE-680824	0314 Activities kitchen	5 ABC	2005		2011	XE-680824	1/14/2016 7:59:59 AM
10 MW-841855	0309 hall nurse station	10 ABC	1995	2007	2013	MW-841855	1/14/2016 8:08:04 AM
11 MW-837363	0310 hall at 29	10 ABC	1995	2007	2013	MW-837363	1/14/2016 8:09:31 AM
12 MW-837362	0311 hall at 38	10 ABC	1995	2007	2013	MW-837362	1/14/2016 8:10:37 AM
13 MW-841854	0312 hall at 17	10 ABC	1995	2007	2013	MW-841854	1/14/2016 8:16:46 AM
14 A892854	:0313 hall Memory lane	10 ABC	2009		2015	A892854	1/14/2016 8:14:59 AM
15 A902248	:0315 Mechanical rm	10 ABC	2009		2015	A902248	1/14/2016 7:45:39 AM
16 XE-680825	0321 oxygen rm	5 ABC	2005		2011	XE-680825	1/14/2016 8:05:27 AM
17 X823939	1598 outdoor pavillion	10 ABC	2010			X823939	1/14/2016 10:00:42 AM
18 AT529943	6374 garage	10 ABC	2011			AT529943	1/14/2016 10:06:53 AM
19 BJ789763	1940 maintenance	10 ABC	2012			BJ789763	1/14/2016 10:05:25 AM
20 BN157724	7139 mini van	2.5 ABC	2013			BN157724	1/14/2016 7:23:57 AM
21 TE-330789	0292 mini van	5 ABC	2002	2015		AQ0002737	1/14/2016 7:24:41 AM
22 XE-680828	0317 bus	5 ABC	2005		2011	XE-680828	1/14/2016 7:22:48 AM
23 J661330	:7632 beacon bus	5 ABC	2009		2015	J661330	1/14/2016 7:25:06 AM
24 X827300	1600 beacon entry	10 ABC	2010			X827300	1/14/2016 10:26:40 AM
25 X823929	1599 beacon rear door	10 ABC	2010			X823929	
26 A901787	:0316 beacon side door	10 ABC	2009		2015	A901787	1/14/2016 10:25:10 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
 Brunswick, Ohio 44212

Fire Extinguishers**Service History**

Order # 11789

JOB LOCATION

Colonial Manor Health Care
 747 South Mount Vernon Avenue
 Loudonville OH 44842

P1: (419)994-4191
 P2:
 F: (419)994-3756

CLIENT

Fire Loss Control, Inc.
 590 Pearl Road
 Brunswick OH 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
---------	----------	-------------	----------	------------	--------	----------	-----------

Extinguisher Work Summary as of 1/14/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
Class K	0	0	1	0	0	0	0	0	1
ABC	2	0	23	0	0	0	0	0	25
Totals	2	0	24	0	0	0	0	0	26

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS