

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers**Service History**

Order # 11816

JOB LOCATION

Olmsted Falls Community Center
8170 Mapleway Drive
Olmsted Falls OH 44138
440-427-1599

Service Date: 1/15/2016

P1: (440)427-1599

P2:
F: (440)235-2265

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick OH 44212

CONTACT

Donna

(440)427-1599

TECHNICIAN

MRO

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 SC-141578	6277 lobby	10 ABC	2000	2012		SC-141578	
2 SC-144925	6278 gym/stairs	10 ABC	2000	2012		SC-144925	
3 XV150588	LL:6279 hall	5 ABC	2006		2012	XV150588	
4 AB269319	2708 kitchen	6 Liter Class K	2006	2016*		AB269319	
5 SA-389503	6281 kitchen	5.5 BC	2000	2012		SA-389503	
6 SC-132272	6282 hall/stairs	10 ABC	2000	2012		SC-132272	
7 XL796256	6283 schuster rm	10 ABC	2005		2011	XL796256	
8 SC-131280	LL:6284 Hall at restroom	10 ABC	2000	2012		SC-131280	
9 SC-131269	1:6285 gym/stairs	10 ABC	2000	2012		SC-131269	
10 SC-144929	6286 projector rm	10 ABC	2000	2012		SC-144929	

Extinguisher Work Summary as of 1/15/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	0	0	8	0	0	0	0	0	8
Class K	1	0	0	0	0	0	0	0	1
BC	0	0	1	0	0	0	0	0	1
Totals	1	0	9	0	0	0	0	0	10

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS