

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 11829

JOB LOCATION

Seasons Health Care
456 Seasons Road
Stow OH 44224
330-688-5553
Service Date: 1/15/2016

P1: (330)688-5553
P2:
F: (330)819-5617

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick OH 44212

CONTACT

Dick Carr

TECHNICIAN

JAL

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Kidde

Model: WHDR-250

Location: Kitchen

Install Date: 6/2008

Last Service: 1/2016

Duct Size: 8" x 18"

Nozzle Type: ADP

Plenum Size: 10" x 6ft

Nozzle Type: ADP

Serial #: 52701

Bar Code: AQ0009358

Timestamp: 1/12/2016 10:38:33 AM

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2008	<input type="checkbox"/>
Monthly		<input type="checkbox"/>
Recharge		<input type="checkbox"/>
Semi-Annual	1/2016	<input checked="" type="checkbox"/>
Flush Piping		<input type="checkbox"/>
New		<input type="checkbox"/>

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1		Extinguishing Agent	2008	2008				

Replacement Parts

Qty	Description	Part No.	Replaced
2	Fuse Links 360°F Globe ML	360ML-11	1/15/2016

Appliances (Left to Right)

Num	Description	Size	Nozzle(s)
1	Range - 6 Burner		R, R

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 1/21/2016 9:57:30 AM

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44212**Fire Suppression Systems
Service History**

Order # 11829

JOB LOCATIONSeasons Health Care
456 Seasons Road
Stow OH 44224
330-688-5553P1: (330)688-5553
P2:
F: (330)819-5617**CLIENT**Fire Loss Control, Inc.
590 Pearl Road
Brunswick OH 44212

Num	Description	Size	Nozzle(s)
2	Grill - 24"		ADP

INSPECTION**I. Fire Suppression Systems**

	Yes	No	NA
1. Hood and appliances properly protected?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Was nozzle/appliance alignment correct upon arrival?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
If not was the alignemt corrected during inspection?			
3. System cylinder gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Cylinder weight or liquid level OK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Fusible links replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Actuation cartridge weight or gauge in operable range? /* Stamped weight 240 g, Actual weigh 450 g */	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. Complete fuel shut-down operational? /* Pneumatic release did not function */	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Remote pull station accessible and operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. All components clean and free of grease?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Nozzle caps cleaned or replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. System meets manufacturer installation instructions?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. System conduit and piping securely mounted?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. Does system meet UL 300 standard?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14. Employees trained in the proper operation of the system?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15. Audible and/or visual alarms functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. System reset and placed back in service?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. System connected to central station?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18. Class K extinguisher present and functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19. Do hood and duct comply with NFPA #96?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. Company State of Ohio Certification # 53-28-1034	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. State of Ohio Certification Jon LeRoy 54-18-1535	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22. State of Ohio Certification Randolph N Kaser 54-18-0381	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
23. Complete Hydrostatic Pressure Test Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24. Complete 6 Year Maintenance Current	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection, Inc. / Fire Loss Control, Inc.

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems

Service History

Order # 11829

JOB LOCATION

Seasons Health Care
456 Seasons Road
Stow OH 44224
330-688-5553

P1: (330)688-5553


P2:

F: (330)819-5617

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick OH 44212

Technician

X 

Jon LeRoy

1/12/2016


Customer Signature

X 

Dick Carr

1/12/2016

Fire Inspector

X 


Dick Carr

1/12/2016

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 1/21/2016 10:01:22 AM