

**Brown Sprinkler Service, Inc.**

2458 State Route 193  
P.O. Box 8  
Dorset, Ohio 44032

**Fire Extinguishers****Service History**

Order # 11961

**JOB LOCATION**

Ashtabula Town Square  
3315 North Ridge East  
440-858-5855  
Ashtabula Ohio 44004  
Service Date: 3/2/2016

P1: (440)998-2020  
P2:  
F:

**CLIENT**

Brown Sprinkler Service, Inc.  
2458 SR 193  
PO Box 8  
Dorset Ohio 44032

**CONTACT**

Cindy Allen

(440)998-2020

**TECHNICIAN**

MRO

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 KP-834925	1:Main entry	10 ABC	1992	2005	2011	AQ0008110	
2 WY-772740	Mall office hall	10 ABC	2005		2011	WY-772740	3/2/2016 8:30:09 AM
3 MV-896606	Spencer	10 ABC	1998	2010	*	AQ0007980	*** Missing ***
4 RE-329587	Spencer	10 ABC	1999	2010	*	RE-329587	*** Missing ***
5 K-708970	Mall office 6yr	2.5 ABC	2009		*	AQ0008124	*** Missing ***
6 XF45173	Maint. shop	5 ABC	2005		2014	XF45173	
7 TB126729	Maint. shop	5 ABC	2002	2015		TB126729	
8 XN-840057	Maint. shop	10 ABC	2005		2014	AQ0007983	
9 XF45146	Mall office	5 ABC	2005		2014	XF45146	
10 SU960864	660	5 ABC	2002	2016*		SU960864	3/2/2016 11:05:33 AM
11 AA464585	1:Wendy's	6 Liter Class K	2004	2015		AA464585	
12 KP-834910	1:Fire hall 9	10 ABC	1992	2005	2011	AQ0008112	3/2/2016 8:35:10 AM
13 KP-834909	1:Fire hall 8	10 ABC	1992	2005	2011	AQ0008113	3/2/2016 8:40:35 AM
14 KP-834907	1:Fire hall 7	10 ABC	1992	2005	2011	AQ0008114	3/2/2016 8:42:01 AM
15 KP-834919	1:K Mart entry	10 ABC	1992	2005	2011	AQ0008115	3/2/2016 8:38:01 AM
16 VN896189	Community rm	5 ABC	2002	2015		VN896189	
17 KM-888183	1:Fire hall 6	10 ABC	1992	2005	2011	AQ0008116	3/2/2016 8:44:13 AM
18 KP-834915	1:Cinema entry	10 ABC	1992	2005	2011	AQ0008117	3/2/2016 8:47:50 AM
19 KP-834926	1:Fire hall 5	10 ABC	1992	2005	2011	AQ0008118	3/2/2016 8:49:55 AM
20 KV-906106	1:Community rm	10 ABC	1993	2006	2014	KV-906106	
21 KM-888182	1:Fire hall 2	10 ABC	1992	2005	2011	AQ0008119	3/2/2016 8:52:51 AM
22 KP-834912	1:Fire hall 4	10 ABC	1992	2005	2011	AQ0008120	3/2/2016 8:54:56 AM
23 KP-834911	1:Fire hall 3	10 ABC	1992	2005	2011	AQ0008121	3/2/2016 8:56:37 AM
24 PN-692777	1:Sears	10 ABC	1998	2010	2016*	PN-692777	3/2/2016 11:44:37 AM
25 SU-913260	1:Sears	10 ABC	2002	2015		AQ0007982	3/2/2016 9:25:20 AM
26 WE-836521	1:Sears mech. rm	10 ABC	2004	*	2010	WE-836521	*** Missing ***
27 SW906933	Sears	10 ABC	2002	2015		SW906933	3/2/2016 9:22:13 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Brown Sprinkler Service, Inc.**

2458 State Route 193  
P.O. Box 8  
Dorset, Ohio 44032

**Fire Extinguishers****Service History**

Order # 11961

**JOB LOCATION**

Ashtabula Town Square  
3315 North Ridge East  
440-858-5855  
Ashtabula Ohio 44004

P1: (440)998-2020  
P2:  
F:

**CLIENT**

Brown Sprinkler Service, Inc.  
2458 SR 193  
PO Box 8  
Dorset Ohio 44032

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
28 SN059580	1:Sears offices	10 ABC	2001	2010	2016*	SN059580	3/2/2016 11:56:25 AM
29 XA103289	1:Sears	10 ABC	2005		2011	XA103289	3/2/2016 9:17:33 AM
30 J-951780	1:Sears dock	10 ABC	2009		2015	J-951780	3/2/2016 9:08:07 AM
31 PN-692771	1:Sears dock	10 ABC	1998	2010	2016*	PN-692771	3/2/2016 12:36:07 PM
32 PN-692624	Sears dock	10 ABC	1998	2010	2016*	PN-692624	3/2/2016 1:37:19 PM
33 PN-692783	1:Sears dock	10 ABC	1998	2010	2016*	PN-692783	3/2/2016 11:52:32 AM
34 Z927629	1:Sears dock	10 ABC	2011			Z927629	3/2/2016 9:09:56 AM
35 Z927288	1:Sears Auto	10 ABC	2011			Z927288	3/2/2016 9:11:06 AM
36 K-025589	1:Sears 6yr	10 ABC	2009		*	K-025589	*** Missing ***
37 N-313437	1:Sears	10 ABC	2010		2016*	N-313437	3/2/2016 12:42:21 PM
38 PN-692793	1:Sears Electrical Room	10 ABC	1998	2010	2016*	PN-692793	3/2/2016 11:54:09 AM
39 VL190856	Sears	10 ABC	2002	2015		VL190856	3/2/2016 9:13:16 AM
40 PN-692769	Sears	10 ABC	1998	2010	2016*	PN-692769	3/2/2016 11:45:59 AM
41 PN-692790	Sears	10 ABC	1998	2010	2016*	PN-692790	3/2/2016 11:49:46 AM
42 PN-692784	Sears	10 ABC	1998	2010	2016*	PN-692784	3/2/2016 12:37:33 PM
43 PN-692778	Sears	10 ABC	1998	2010	2016*	PN-692778	3/2/2016 11:48:41 AM
44 PN-692786	Sears	10 ABC	1998	2010	2016*	PN-692786	3/2/2016 11:47:21 AM
45 PN-692779	Sears	10 ABC	1998	2010	2016*	PN-692779	3/2/2016 12:41:52 PM
46 XF45182	S&B	5 ABC	2005		2014	XF45182	3/2/2016 9:36:28 AM
47 XF45176	S&B	5 ABC	2005		2014	XF45176	
48 XF45124	S&B	5 ABC	2005		2014	XF45124	
49 XF45134	S&B	5 ABC	2005		2014	XF45134	
50 KR-946660	Unit 600	5 ABC	1992	2010	2016*	AQ0008125	3/2/2016 1:06:22 PM
51 KR-946622	:Unit 600	5 ABC	1992	2010	2016*	AQ0008126	3/2/2016 1:05:48 PM
52 KR-946610	Unit 600	5 ABC	1992	2010	2016*	AQ0008127	3/2/2016 1:02:08 PM
53 KH-838036	Unit 600	5 ABC	1992	2010	2016*	AQ0008128	3/2/2016 1:13:44 PM
54 KR-946651	:Unit 600	5 ABC	1992	2010	2016*	AQ0008129	3/2/2016 1:17:16 PM
55 KR-946645	:Unit 600	5 ABC	1992	2010	2016*	AQ0008130	3/2/2016 1:03:55 PM
56 KR-849150	Unit 600	5 ABC	1992	2010	2016*	AQ0008131	3/2/2016 1:18:20 PM
57 KR-849165	Unit 600	5 ABC	1992	2010	2016*	AQ0008132	3/2/2016 10:03:47 AM
58 KR-946644	Unit 600	5 ABC	1992	2010	2016*	AQ0008133	3/2/2016 1:15:24 PM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Brown Sprinkler Service, Inc.**

2458 State Route 193  
 P.O. Box 8  
 Dorset, Ohio 44032

**Fire Extinguishers**

**Service History**

Order # 11961

**JOB LOCATION**

Ashtabula Town Square  
 3315 North Ridge East  
 440-858-5855  
 Astabula Ohio 44004

P1: (440)998-2020  
 P2:  
 F:

**CLIENT**

Brown Sprinkler Service, Inc.  
 2458 SR 193  
 PO Box 8  
 Dorset Ohio 44032

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
59 KR-849166	Unit 600	5 ABC	1992	2010	2016*	AQ0008134	3/2/2016 1:07:46 PM
60 KR-843667	Unit 600	5 ABC	1992	2010	2016*	AQ0008135	3/2/2016 1:00:49 PM
61 KR-849140	Unit 600	5 ABC	1992	2010	2016*	AQ0008136	3/2/2016 1:19:20 PM
62 KR-946646	Unit 600	5 ABC	1992	2010	2016*	AQ0008137	3/2/2016 1:08:43 PM
63 JY-00154251	Unit 600	10 ABC	1991	2010	2016*	AQ0008138	3/2/2016 1:09:25 PM
64 VK573388	Unit 600	10 ABC	2002	2015		VK573388	

Extinguisher Work Summary as of 3/2/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	1	27	30	0	0	0	0	5	63
Class K	0	0	1	0	0	0	0	0	1
Totals	1	27	31	0	0	0	0	5	64

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS