

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 12117

JOB LOCATION

Lakewood Fire Station 3
12567 Clifton Blvd
Lakewood Ohio 44107
216-529-6818 Kurt Cell
Service Date: 3/9/2016

P1:
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

CONTACT

Tim Dunphy

TECHNICIAN

JAL

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Amerex

Model: KP 2.75

Location: kitchen

Install Date: 11/2015

Last Service: 3/9/2016

Duct Size: 12" x 12"

Nozzle Type: 16416

Plenum Size: 18" x 72"

Nozzle Type: 11982

Serial #: A-21251

Bar Code: AQ10059

Timestamp:

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2015	☐
Monthly		☐
Recharge		☐
Semi-Annual	3/2016	☒
Flush Piping		☐
New	11/23/2015	☐

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	2.75	Extinguishing Agent	2015	2015		A-21251		

Replacement Parts

Qty	Description	Part No.	Replaced
2	Fuse Links 450°F Globe ML	450ML-11	3/4/2015
8	Detection Tubing Cleaned		11/2015
5	Amerex Nozzle Cap	12334	11/2015

Appliances (Left to Right)

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 12117

JOB LOCATION

Lakewood Fire Station 3
12567 Clifton Blvd
Lakewood Ohio 44107
216-529-6818 Kurt Cell

P1:
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num	Description	Size	Nozzle(s)
1	Range - 10 Burner	60"	2-14178, 11982

INSPECTION**I. Fire Suppression Systems**

	Yes	No	NA
1. Hood and appliances properly protected?	☒	☐	☐
2. Was nozzle/appliance alignment correct upon arrival?	☒	☐	☐
If not was the alignment corrected during inspection?			
3. System cylinder gauge in operable range?	☒	☐	☐
4. Cylinder weight or liquid level OK?	☒	☐	☐
5. Actuation cartridge weight or gauge in operable range?	☒	☐	☐
/* Pressure gage reading 2000PSI */			
6. Detection tubing cleaned and checked for damage?	☒	☐	☐
7. Complete fuel shut-down operational?	☒	☐	☐
8. Remote pull station accessible and operational?	☒	☐	☐
9. All components clean and free of grease?	☒	☐	☐
10. Nozzle caps cleaned or replaced?	☒	☐	☐
11. System meets manufacturer installation instructions?	☒	☐	☐
12. System conduit and piping securely mounted?	☒	☐	☐
13. Does system meet UL 300 standard?	☒	☐	☐
14. Employees trained in the proper operation of the system?	☒	☐	☐
15. Audible and/or visual alarms functional?	☒	☐	☐
16. System reset and placed back in service?	☒	☐	☐
17. System connected to central station?	☒	☐	☐
18. Class K extinguisher present and functional?	☒	☐	☐
19. Do hood and duct comply with NFPA #96?	☒	☐	☐
20. State of Ohio Certification # 53-28-1034	☒	☐	☐
21. State of Ohio Certification Jon LeRoy 54-18-1535	☒	☐	☐
22. State of Ohio Certification Marcus R Orahod 54-78-1475	☐	☐	☒
23. Complete Hydrostatic Pressure Test Current	☒	☐	☐
24. Complete 6 Year Maintenance Current	☐	☐	☒

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection Inc,

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 12117

JOB LOCATION

Lakewood Fire Station 3
12567 Clifton Blvd
Lakewood Ohio 44107
216-529-6818 Kurt Cell

P1:
P2:
F:

CLIENT


Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

INSPECTION**I. Fire Suppression Systems**

Yes No NA

17012 Kinsman Road
Middelfield, Ohio 44062
1-877-443-5532

Technician

X 

Jon LeRoy

3/9/2016

Customer Signature

X _____

Fire Inspector

X _____

*** End Report: 1 ***

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS