

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers**Service History**

Order # 11968

JOB LOCATION

National Carpet Mill Outlet
960 LaFayette Road
Medina Ohio 44256
330-721-1914

Service Date: 2/19/2016

P1: (330)721-1914

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

CONTACT

Lorie

TECHNICIAN

MRO

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 XR541976	0593 ft door	10 ABC	2006		2012	XR541976	
2 WE17611	0591 garage dr	20 ABC	2004	2016*		WE17611	
3 SV-194496	0590 West side door	10 ABC	2002	2015		SV-194496	2/19/2016 11:17:47 AM
4 XZ650445	0588 Rear exit	10 ABC	2006		2012	XZ650445	
5 MC-782157	0589 Rear showroom	20 ABC	1994	2006	2012	MC-782157	
6 PN-563423	0587 Rear dock	10 ABC	1998	2010	2016*	PN-563423	
7 XW7975	0594 Hardwood display	10 ABC	2006		2012	XW7975	
8 XR532430	0586 office	10 ABC	2006		2012	XR532430	
9 MC-782160	0592 Middle showroom	20 ABC	1994	2006	2012	MC-782160	

Extinguisher Work Summary as of 2/19/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	1	1	7	0	0	0	0	0	9
Totals	1	1	7	0	0	0	0	0	9

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS