

Acquire Fire Protection, Inc.17012 Kinsman Road
Middlefield, Ohio 44062**Fire Suppression Systems****Service History**

Order # 12003

JOB LOCATIONReliable Cabinets, Inc.
45300 US Hwy 20
440-774-8099
Oberlin OH 44074
Service Date: 2/25/2016P1: 440-774-8099x102
P2: (440)897-1170
F: (440)774-9020**CLIENT**Reliable Cabinets, Inc.
45300 US Hwy 20
Oberlin OH 44074**CONTACT**

Russ Heist

TECHNICIAN

JAL

Fire Suppression System

Num: 1

Type: Dry Chemical Extinguishing System

Manufacturer: Amerex

Model: Amerex IS-35

Location: Spray Booth

Install Date: 11/5/2008

Last Service: 8/19/2015

Serial #:

Bar Code: AQ0008102

Timestamp: 2/25/2016 8:29:36 AM

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2007	<input type="checkbox"/>
6 Year	2015	<input type="checkbox"/>
Monthly		<input type="checkbox"/>
Recharge		<input type="checkbox"/>
Semi-Annual	2/2016	<input checked="" type="checkbox"/>
New	11/6/2008	<input type="checkbox"/>

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	35	Extinguishing Agent	4/2007	2007	2015	TAN015025		
2	35	Extinguishing Agent	8/2007	2007	2015	TAN01439		

Replacement Parts

Qty	Description	Part No.	Replaced
30	Tubing		8/2015
2	AAA Battery	ALK 92	2/25/2016

INSPECTION**I. Fire Suppression Systems**

Yes No NA

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 3/2/2016 11:42:35 AM

Acquire Fire Protection, Inc.

17012 Kinsman Road
Middlefield, Ohio 44062

Fire Suppression Systems

Service History

Order # 12003

JOB LOCATION

Reliable Cabinets, Inc.
45300 US Hwy 20
440-774-8099
Oberlin OH 44074

CLIENT

P1: 440-774-8099x102
P2: (440)897-1170
F: (440)774-9020
Reliable Cabinets, Inc.
45300 US Hwy 20
Oberlin OH 44074

INSPECTION

I. Fire Suppression Systems

	Yes	No	NA
1. System cylinder gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Cylinder weight OK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Actuation cartridge weight or gauge in operable range? /* Pressure gage reading 2000PSI */	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Detection tubing cleaned and checked for damage?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Complete fuel shut-down operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Remote pull station accessible and operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. All components clean and free of overspray?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Nozzle caps cleaned or replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. System meets manufacturer installation instructions?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. System conduit and piping securely mounted?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. Employees trained in the proper operation of the system?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. Audible and/or visual alarms functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. System reset and placed back in service?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14. System connected to central station?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15. State of Ohio Certification # 53-28-1034	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. State of Ohio Certification Jon LeRoy 54-18-1535	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. State of Ohio Certification Marcus R Orahood 54-78-1475	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
18. Complete Hydrostatic Pressure Test Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
New Value			
19. Complete 6 Year Maintenance Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection Inc,
17012 Kinsman Road
Middlefield, Ohio 44062
1-877-443-5532

Technician

X 

Jon LeRoy

Customer Signature

X _____

2/25/2016

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Acquire Fire Protection, Inc.

17012 Kinsman Road
Middlefield, Ohio 44062

Fire Suppression Systems

Service History

Order # 12003

JOB LOCATION

Reliable Cabinets, Inc.
45300 US Hwy 20
440-774-8099
Oberlin OH 44074

P1: 440-774-8099x102
P2: (440)897-1170
F: (440)774-9020

CLIENT

Reliable Cabinets, Inc.
45300 US Hwy 20
Oberlin OH 44074

Fire Inspector

X

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 3/2/2016 11:42:35 AM