

Fire Loss Control, Inc.

590 Pearl Road
 Brunswick, Ohio 44062

Fire Extinguishers**Service History**

Order # 12031

JOB LOCATION

Seasons Health Care
 456 Seasons Road
 Stow OH 44224
 330-688-5553
 Service Date: 3/21/2016

P1: (330)688-5553
 P2:
 F: (330)819-5617

CLIENT

Fire Loss Control, Inc.
 590 Pearl Road
 Brunswick OH 44212

CONTACT

Dick Carr

TECHNICIAN

JAL

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 RT-319541	651 Manin Enrtry	10 ABC	2000	2012		RT-319541	3/21/2016 10:55:49 AM
2 E619908	652 office hall	10 ABC	2009		2015	E619908	3/21/2016 10:57:56 AM
3 J662705	653 PT	5 ABC	2009		2015	J662705	3/21/2016 11:01:08 AM
4 VY855979	654 TV rm	10 ABC	2003	2016*		VY855979	3/21/2016 11:59:29 AM
5 WA287899	655 rm 23	10 ABC	2003	2015	2015	WA287899	3/21/2016 11:08:17 AM
6 SW908230	656 Nurses station	10 ABC	2002	2015		SW908230	
7 WD209928	666 Nurses store rm	10 ABC	2003	2016*		WD209928	3/21/2016 11:43:19 AM
8 WA308868	657 RM 5 At exit	10 ABC	2003	2015		WA308868	3/21/2016 11:13:02 AM
9 VN-632734	661 At dinning rm	10 ABC	2003	2015		AQ0003266	3/21/2016 11:15:33 AM
10 WA287916	658 Dietary closet	10 ABC	2003	2015		WA287916	3/21/2016 11:18:35 AM
11 W-0282601	659 Kitchen	6 Liter Class K	2001	2012		W-0282601	
12 B13779756	660 kitchen	5 ABC	2016			B13779756	3/21/2016 11:36:12 AM
13 KT-474818	662 Courtyard	5 ABC	1993	2015		KT-474818	3/21/2016 11:38:36 AM
14 VZ515450	663 Break rm	5 ABC	2003	2016*		VZ515450	3/21/2016 11:46:36 AM
15 SZ427454	LL:665 laundry	10 ABC	2002	2016*		SZ427454	3/21/2016 11:52:13 AM
16 VY877480	LL:664 bsmt	10 ABC	2003	2016*		VY877480	3/21/2016 11:50:49 AM
17 AU81229	white bus	2.5 ABC	2012			AU81229	

Extinguisher Work Summary as of 3/21/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	5	0	10	0	0	1	0	0	16
Class K	0	0	1	0	0	0	0	0	1
Totals	5	0	11	0	0	1	0	0	17

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44062

Fire Extinguishers

Service History

Order # 12031

JOB LOCATION

Seasons Health Care
456 Seasons Road
Stow OH 44224
330-688-5553

P1: (330)688-5553

P2:

F: (330)819-5617

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick OH 44212

Exhibits

456 Seasons Road, Stow OH 44224, 330-688-5553 FE

3/20/2016 2:12:38 PM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS