

Acquire Fire Protection, Inc.590 Pearl Road
Brunswick, Ohio 44062**Fire Extinguishers****Service History**

Order # 12106

JOB LOCATIONThe Country Club
2825 Lander Road
Pepper Pike OH 44124-4899
216-831-9200P2: (216)408-9592
F: (216)514-0892

Service Date: 3/28/2016

CLIENTThe Country Club
2825 Lander Road
Pepper Pike OH 44124-4899**CONTACT**Scott Ryan
nmarkel@thecountryclub.co**TECHNICIAN**

MRO

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 ZL285345	:kitchen	10 ABC	2008		2014	ZL285345	3/14/2016 2:12:26 PM
2 AB186352	kitchen	1.5 Class K	2006	2016*		AB186352	3/14/2016 12:58:10 PM
3 AB955178	kitchen	6 liter Class K	2009	2015		AB955178	3/14/2016 9:40:46 AM
4 V-444062	kitchen	1.5 Class K	1995	2016*		V-444062	3/14/2016 1:03:12 PM
5 RH-308614	upper wait area	10 ABC	1999	2/11/2011		RH-308614	
6 WZ979145	:service hall/dock	10 ABC	2005		3/12/2013	WZ979145	3/14/2016 10:40:25 AM
7 RF-174056	locker room locker 373	10 ABC	1999	2/11/2011		RF-174056	
8 WD258700	locker room Hydro	10 ABC	2003	2015		WD258700	3/14/2016 10:09:18 AM
9 XB578624	member hall to Crystal room	10 ABC	2005		2/11/2011	XB578624	3/14/2016 9:48:41 AM
10 PF-275348	2:laundry	5 ABC	1997	2007	3/12/2013	PF-275348	3/14/2016 11:23:08 AM
11 RT-243504	ladies entrance hall	10 ABC	2000	2/27/2012		RT-243504	3/14/2016 9:50:32 AM
12 SM964070	mens front restroom	10 ABC	2001	3/12/2013		SM964070	
13 RH-308603	Attic:south	10 ABC	1999	2/11/2011		RH-308603	3/14/2016 11:30:33 AM
14 SM962168	hall by attic	10 ABC	2001	3/12/2013		SM962168	3/14/2016 11:28:59 AM
15 SM957735	2:ladies locker room hall	10 ABC	2001	3/12/2013		SM957735	3/14/2016 11:33:32 AM
16 RH-013631	ladies locker room attendant	5 ABC	1999	2/11/2011		RH-013631	3/14/2016 11:35:54 AM
17 A456-95	boardroom	10 ABC	1995	2014		MV-586100	3/14/2016 11:38:15 AM
18 RH-308600	2:board room	10 ABC	1999	2/11/2011		RH-308600	3/14/2016 10:02:36 AM
19 SM964068	2:accounting steps	10 ABC	2001	3/12/2013		SM964068	3/14/2016 9:57:17 AM
20 SN-802442	2:accounting	10 ABC	2001	2014		SN-802442	3/14/2016 9:59:29 AM
21 SZ447556	accounting hall	10 ABC	2002	2016*		SZ447556	3/14/2016 11:58:20 AM
22 SM957738	1:coat room	10 ABC	2001	3/12/2013		SM957738	3/14/2016 11:08:46 AM
23 T065906	front office	5 HALON	1990	2/11/2011		CF-0004904	3/14/2016 11:06:56 AM
24 PV-199863	1:south bar	5 ABC	1999	2010	2016*	PV-199863	3/14/2016 12:42:09 PM
25 WZ982001	elevator room	10 ABC	2005		2/11/2011	WZ982001	3/14/2016 11:02:48 AM
26 SM964067	south sprinklerroom	10 ABC	2001	3/12/2013		SM964067	3/14/2016 1:23:02 PM
27 WZ974766	Zelma hall	10 ABC	2005		2/11/2011	WZ974766	3/14/2016 10:18:31 AM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Acquire Fire Protection, Inc.590 Pearl Road
Brunswick, Ohio 44062**Fire Extinguishers****Service History**

Order # 12106

JOB LOCATIONThe Country Club
2825 Lander Road
Pepper Pike OH 44124-4899
216-831-9200P2: (216)408-9592
F: (216)514-0892**CLIENT**The Country Club
2825 Lander Road
Pepper Pike OH 44124-4899

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
28 AB248079	:Zelmas Grille	1.5 Class K	2006	2016*		XK01-2	3/21/2016 7:08:11 AM
29 RF-171810	Zelmas Grille	10 ABC	1999	2/11/2011		RF-171810	3/14/2016 10:16:43 AM
30 RF-171325	Basement :laundry	10 ABC	1999	2/11/2011		RF-171325	3/14/2016 10:21:35 AM
31 SV8952111	basement:basement	10 ABC	2001	2014		AQ0007067	3/14/2016 10:30:08 AM
32 VK567227	basement :basement	10 ABC	2002	2015		VK567227	3/14/2016 10:25:43 AM
33 ZL286495	basement :basement	10 ABC	2008		2015	ZL286495	3/14/2016 10:38:23 AM
35 VK5142750	basement:maintenan ce	10 ABC	2002	2014		AQ0006581	3/14/2016 9:38:21 AM
36 RF-170805	basement :maintenance hall	10 ABC	1999	2/11/2011		RF-170805	3/14/2016 10:52:17 AM
37 SM959231	sub panel room	10 ABC		3/12/2013		SM959231	3/14/2016 10:53:35 AM
38 AA604456	basement:spare	2.5 gal PW	2004	2016*		AA604456	3/14/2016 10:37:17 AM
39 RH-013628	basement :spare	5 ABC	1999	2/11/2011		RH-013628	3/14/2016 10:35:59 AM
40 T284746	basement :spare	5 HALON	1990	2/11/2011		CF-0004909	3/14/2016 10:47:09 AM
41 JD925590	greens office	10 ABC	1989	2/11/2011		CF-0002249	3/14/2016 2:37:25 PM
42 SH843741	greens pesticide	10 ABC	2001	3/12/2013		SH843741	3/21/2016 8:34:41 AM
43 M375605	greens maintenance	10 ABC	2009		2015	M375605	3/21/2016 8:26:50 AM
45 NY-848698	greens maintenance	10 ABC	1997	2010	2016*	NY-848698	3/21/2016 8:32:24 AM
46 M376061	greens maintenance 6yr	10 ABC	2009		2015	M376061	3/14/2016 2:31:26 PM
47 MR-886372	greens maintenance	10 ABC	1995	2007	3/12/2013	MR-886372	3/14/2016 2:34:33 PM
48 RE-212304	greens maintenance	2.5 ABC	1999	2/11/2011		AQ0007542	*** Missing ***
49 M371682	greens maintenance	10 ABC	2009		2015	M371682	3/14/2016 3:07:03 PM
50 RE-213128	greens maintenance	2.5 ABC	1999	2/11/2011		AQ0007537	3/14/2016 3:05:08 PM
51 VS241565	Wash bay	10 ABC	2003	2016*		VS241565	3/21/2016 8:01:19 AM
52 PF-990045	pump house	10 ABC	1998	2010	2016*	PF-990045	
53 NY-898179	kitchen elevator room	10 ABC	1997	2010	2016*	NY-898179	3/14/2016 12:49:24 PM
54 CF-0014054	Boiler Room	10 ABC	1987	2010	2016*	CF-0014054	3/14/2016 12:49:48 PM
55 VY886209	Guest room D	10 ABC	2004	2016*		VY886209	3/14/2016 12:01:37 PM
56 ZL285492	:Sleeping guest room C	10 ABC	2008		2014	ZL285492	3/14/2016 2:42:55 PM
57 RH-013640	Golf shop rear	5 ABC	1999	2009	2016*	RH-013640	
59 VZ515716	skeet	5 ABC	2003	2016*		VZ515716	

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Acquire Fire Protection, Inc.

590 Pearl Road
Brunswick, Ohio 44062

Fire Extinguishers

Service History

Order # 12106

JOB LOCATION

The Country Club
2825 Lander Road
Pepper Pike OH 44124-4899
216-831-9200

CLIENT

The Country Club
2825 Lander Road
Pepper Pike OH 44124-4899

P2: (216)408-9592
F: (216)514-0892

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
60 PV-199830	Golf shop	5 ABC	1998	2010	2016*	PV-199830	
61 JL-061550	spare	2.5 ABC	1990	2015		AQ0008692	3/14/2016 10:50:13 AM
62 SU-740317	spare	2.5 ABC	2002	2015		AQ0006637	3/14/2016 10:49:03 AM
63 AA458114	spare	6 Liter Class K	2004	2015		AA458114	3/14/2016 1:44:09 PM
64 AA643169	spare	6 Liter Class K	2004	2016*		AA643169	3/14/2016 1:14:34 PM
65 SM957734	Mens locker room	10 ABC	2001	3/12/2013		SM957734	3/14/2016 10:11:50 AM
66 RK-243552	greens maintenance	2.5 ABC	1999	2011		AQ0007543	3/14/2016 2:33:19 PM
67 AC207028	:Tennis shop	6 Liter Class K	2010	2016*		AC207028	3/14/2016 1:00:59 PM
68 NW-087421	Cart barn	10 ABC	1997	2008	2013	NW-087421	*** Missing ***
69 SM960530	Cart Barn	10 ABC	2001	3/12/2013		SM960530	3/14/2016 2:45:07 PM
70 RH-013662	Paddle house	5 ABC	1999	3/12/2013		RH-013662	3/14/2016 1:47:53 PM
71 RP-579104	Spare	10 ABC	2000	3/12/2013		RP-579104	3/14/2016 10:45:36 AM
72 TB739252	Spare	10 ABC	2002	3/12/2013		TB739252	3/14/2016 10:42:59 AM
73 WZ978452	1:Family room north hall	10 ABC	2005		2/11/2011	WZ978452	3/14/2016 9:44:11 AM
74 YF888656	treatment plant	10 ABC	2007	2014		YF888656	*** Missing ***
75 WS472282	greens mantince	2.5 ABC	2004	2016*		WS472282	3/14/2016 3:01:04 PM
76 VR132953	Bed Room	10 ABC	2003	2016*		VR132953	

Extinguisher Work Summary as of 3/28/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	6	7	46	0	1	0	0	3	63
Class K	5	0	2	0	0	0	0	0	7
HALON	0	0	2	0	0	0	0	0	2
PW	1	0	0	0	0	0	0	0	1
Totals	12	7	50	0	1	0	0	3	73

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Acquire Fire Protection, Inc.

590 Pearl Road
Brunswick, Ohio 44062

Fire Extinguishers

Service History

Order # 12106

JOB LOCATION

The Country Club
2825 Lander Road
Pepper Pike OH 44124-4899
216-831-9200

P2: (216)408-9592
F: (216)514-0892

CLIENT

The Country Club
2825 Lander Road
Pepper Pike OH 44124-4899

Exhibits

2825 Lander Road, Pepper Pike OH 44124-4899, 216-831-920 FE

3/14/2016 12:21:56 PM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS