

Acquire Fire Protection, Inc.17012 Kinsman Road
Middlefield, Ohio 44062**Fire Suppression Systems****Service History**

Order # 11984

JOB LOCATIONWilloughby United Methodist
15 Public Square
(440)942-9068
Willoughby OH 44094
Service Date: 2/19/2016

wlbyumc@amertech.net

P1: (440)942-9068
P2:
F: (440)942-6953**CLIENT**Willoughby United Methodist
15 Public Square
Willoughby OH 44094**CONTACT**

Judy Dort

(440)942-9068

TECHNICIAN

JAL

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Ansul

Model: R102 4.5 Gallon

Location: Kitchen

Install Date: 2001

Last Service: 8/12/2015

Duct Size: 14 X 20

Nozzle Type: 2 - 2W

Plenum Size: 14 Ft

Nozzle Type: 2 - 1N

Serial #: R 185192

Bar Code: AQ0001124

Timestamp: 2/19/2016 9:00:58 AM

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2013	<input type="checkbox"/>
Monthly		<input type="checkbox"/>
Recharge		<input type="checkbox"/>
Semi-Annual	2/2016	<input checked="" type="checkbox"/>
Flush Piping		<input type="checkbox"/>
New		<input type="checkbox"/>

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	1.5	Extinguishing Agent	2001	2013			AQ0001122	2/7/2013 9:36:20 AM
2	3	Extinguishing Agent	2013	2013		20130303998	AQ0001123	2/7/2013 9:36:04 AM

Replacement Parts

Qty	Description	Part No.	Replaced
4	Fuse Links 360°F K Link	360K-11	2/19/2016
11	Ansul Nozzle Cap	AS77695	8/2014

Appliances (Left to Right)

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 3/2/2016 11:40:46 AM

Acquire Fire Protection, Inc.17012 Kinsman Road
Middlefield, Ohio 44062**Fire Suppression Systems****Service History**

Order # 11984

JOB LOCATIONWilloughby United Methodist
15 Public Square
(440)942-9068
Willoughby OH 44094

wlbyumc@amertech.net

P1: (440)942-9068

P2:

F: (440)942-6953

CLIENTWilloughby United Methodist
15 Public Square
Willoughby OH 44094

Num	Description	Size	Nozzle(s)
1	Convvection Oven	Disconnecte	N\A, 245
2	Range - 6 Burner	28X36	F1, 245
3	Range - 6 Burner		F1, 245

INSPECTION**I. Fire Suppression Systems**

	Yes	No	NA
1. Hood and appliances properly protected?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Was nozzle/appliance alignment correct upon arrival?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
If not was the alignemnt corrected during inspection?			
3. System cylinder gauge in operable range?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4. Cylinder weight or liquid level OK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Fusible links replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Actuation cartridge weight or gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
/* Stamped weight 58 5\8 oz, Actual weight 58 3\4 oz */			
7. Complete fuel shut-down operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Remote pull station accessible and operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. All components clean and free of grease?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Nozzle caps cleaned or replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. System meets manufacturer installation instructions?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. System conduit and piping securely mounted?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. Does system meet UL 300 standard?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14. Employees trained in the proper operation of the system?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15. Audible and/or visual alarms functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. System reset and placed back in service?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. System connected to central station?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18. Class K extinguisher present and functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19. Do hood and duct comply with NFPA #96?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. Company State of Ohio Certification # 53-28-1034	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. State of Ohio Certification Jon LeRoy 54-18-1535	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22. State of Ohio Certification Marcus R Orahood 54-78-1475	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
23. Complete Hydrostatic Pressure Test Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24. Complete 6 Year Maintenance Current	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection, Inc. / Fire Loss Control, Inc.

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 3/2/2016 11:40:46 AM

Acquire Fire Protection, Inc.

17012 Kinsman Road
Middlefield, Ohio 44062

Fire Suppression Systems

Service History

Order # 11984

JOB LOCATION

Willoughby United Methodist
15 Public Square
(440)942-9068
Willoughby OH 44094


wlbyumc@amertech.net

P1: (440)942-9068
P2:
F: (440)942-6953

CLIENT

Willoughby United Methodist
15 Public Square
Willoughby OH 44094

Technician

X 

Jon LeRoy

2/19/2016

Customer Signature

X _____

Fire Inspector

X 

Mike Kocab

2/19/2016

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 3/2/2016 11:40:46 AM