

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44062**Fire Extinguishers****Service History**

Order # 12143

JOB LOCATIONFBC Chemical Corporation
900 West Smith Road
Medina Ohio 44256
330-723-7780

Service Date: 4/22/2016

P1: (330)723-7780

P2:

F:

CLIENTFire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212**CONTACT**

Dennis Kelm

TECHNICIAN

MRO

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 AX993361	7972 entrance	20 ABC	2012			AX993361	
2 AH33177	8111 J1 Storage WH	20 ABC	2011			AH33177	
3 YD754978	8110 Pump rm	20 ABC	2006		2013	YD754978	
4 ZU300021	8109 Pump rm	20 ABC	2008		2014	ZU300021	
5 ZU300027	8108 Pump rm	20 ABC	2008		2014	ZU300027	
6 YM948568	7978 K19 storage WH	20 ABC	2007		2013	YM948568	
7 S951331	7977 G27 storage WH	20 ABC	2010		2016*	S951331	
8 YM950452	7976 G23 storage WH	20 ABC	2007		2013	YM950452	
9 S951336	7975 G13 Storage WH	20 ABC	2010		2016*	S951336	
10 S951339	7974 G1 Storage WH	20 ABC	2010		2016*	S951339	
11 V691226	7973 Storage LD	10 ABC	2010		2016*	V691226	
12 AB659387	7982 Sprinkler riser rm	15.5 CO2	2010	2015		AB659387	*** Missing ***
13 AY170919	7979 Chemical WH	20 ABC	2012			AY170919	
14 AY871063	7980 Chemical WH	20 ABC	2012			AY871063	
15 AY871081	7981 Chemical WH	20 ABC	2012			AY871081	
16 AY178166	7983 Chemical WH	20 ABC	2012			AY178166	
17 AY178180	7984 Chemical WH	20 ABC	2012			AY178180	4/22/2016 8:57:51 AM
18 F940657	7998 break rm	10 ABC	2009		2015	F940657	4/22/2016 11:56:04 AM
19 YS264530	7990 Office hall	10 ABC	2007		2013	YS264530	4/22/2016 8:50:12 AM
20 YL93891	:7999 Office hall	10 ABC	2007		2013	YL93891	4/22/2016 8:52:44 AM
21 VR150537	7996 Offices	10 ABC	2003	2015		VR150537	4/22/2016 8:54:47 AM
22 ZU300014	7992 Chemical WH	20 ABC	2008		2014	ZU300014	
23 F941905	8000 maintenance	10 ABC	2009		2015	F941905	4/22/2016 11:55:21 AM
24 F942402	8101 Wash bay	10 ABC	2009		2015	F942402	
25 AY170946	8102 Chemical WH	20 ABC	2012			AY170946	
26 AK550704	8104 Small Chemical RM	20 ABC	2011			AK550704	

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44062**Fire Extinguishers****Service History**

Order # 12143

JOB LOCATIONFBC Chemical Corporation
900 West Smith Road
Medina Ohio 44256
330-723-7780P1: (330)723-7780
P2:
F:**CLIENT**Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
27 YL119045	8105 Small Chemical RM	10 ABC	2007		2013	YL119045	
28 S951341	8103 Small Chemical RM	20 ABC	2010		2016*	S951341	4/22/2016 11:46:53 AM
29 S951335	8112 Chemical WH	20 ABC	2010		2016*	S951335	4/22/2016 11:07:11 AM
30 YL90104	7985 Corning WH	10 ABC	2007		2013	YL90104	4/22/2016 8:59:22 AM
31 YS273988	7986 Corning WH	10 ABC	2007		2013	YS273988	
32 U-813995	7987 Sprinkler pump rm	15.5 CO2	1992	2012		AQ0008385	4/22/2016 12:02:54 PM
33 YL92707	7988 Corning WH	10 ABC	2007		2013	YL92707	4/22/2016 9:02:35 AM
34 ZM585463	7989 Corning WH	20 ABC	2008		2014	ZM585463	
35 BF72744	7966 Tank farm	20 ABC	2012			BF72744	4/22/2016 9:38:14 AM
36 BF72751	7971 Tank farm	20 ABC	2012			BF72751	4/22/2016 9:31:49 AM
37 YU838565	7968 Tank farm	20 ABC	2007		2013	YU838565	4/22/2016 9:53:50 AM
38 YU838550	7970 Tank farm	20 ABC	2007		2013	YU838550	4/22/2016 9:56:16 AM
39 YU837876	7967 Tank farm	20 ABC	2007		2013	YU837876	4/22/2016 9:59:03 AM
40 YU842973	7969 Tank farm	20 ABC	2007		2013	YU842973	4/22/2016 9:50:59 AM
41 BN163418	7748 Fork lift #2	2.5 ABC	2013			AQ0008378	4/22/2016 8:06:42 AM
42 AT851354	7750 Fork lift #1	2.5 ABC	2013			AQ0008380	4/22/2016 8:09:06 AM
43 BR768821	8151 Fork lift #3	2.5 ABC	2013			AQ0008381	4/22/2016 8:36:35 AM
44 ZL464291	8107 Fork lift	2.5 ABC	2013			AQ0008382	*** Missing ***
45 ZL444751	Yale fork lift	2.5 ABC	2008		2014	AQ0008383	4/22/2016 8:26:03 AM
46 AH618177	8113 Spare	10 ABC	2011			AH618177	4/22/2016 8:18:59 AM
47 BR768822	8152 Spare	2.5 ABC	2013			AQ0008379	4/22/2016 8:19:17 AM
48 WE48226	7995 spare	10 ABC	2004	2016*		WE48226	4/22/2016 11:55:53 AM
49 WF-02952	7994 spare	10 ABC	2004	2016*		WF-02952	4/22/2016 11:55:39 AM
50 BB747268	7997 spare	10 ABC	2012			BB747268	4/22/2016 8:44:15 AM
51 YS269089	7991 Spare	10 ABC	2007		2013	YS269089	4/22/2016 8:43:24 AM
52 ZM585452	sprinkler pump room***	20 ABC	2008		2014	ZM585452	4/22/2016 9:28:06 AM
53 AV-961364	8116 truck #001	5 ABC	2012			AQ0008388	4/22/2016 12:14:33 PM
54 AV-961526	8115 truck #002	5 ABC	2012			AQ0008384	*** Missing ***
55 BR785351	8117 Truck 108	2.5 ABC	2013		2014	BR785351	4/22/2016 9:35:23 AM
56 AQ000838	Truck 705	5 ABC	2008		2014	AQ0008386	*** Missing ***

6

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44062**Fire Extinguishers****Service History**

Order # 12143

JOB LOCATIONFBC Chemical Corporation
900 West Smith Road
Medina Ohio 44256
330-723-7780

P1: (330)723-7780

P2:

F:

CLIENTFire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
57 LY-457191	Truck 805	5 ABC	2001	2012		AQ09567	4/22/2016 9:46:27 AM
58 YU842967	fuel tank farm	20 ABC	2007		2015	YU842967	*** Missing ***
59 BB792758	maintenance office	2.5 ABC	2012			BB792758	4/22/2016 8:42:12 AM
60 AV961567	Spare	5 ABC	2012			AQ09566	4/22/2016 8:21:42 AM
61 A99562205	Fork lift	2.5 ABC	2015			AQ09568	4/22/2016 11:49:29 AM

Extinguisher Work Summary as of 4/22/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	2	6	47	0	0	0	0	4	59
CO2	0	0	1	0	0	0	0	1	2
Totals	2	6	48	0	0	0	0	5	61

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44062

Fire Extinguishers

Service History

Order # 12143

JOB LOCATION

FBC Chemical Corporation
900 West Smith Road
Medina Ohio 44256
330-723-7780

P1: (330)723-7780

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Exhibits

900 West Smith Road, Medina Ohio 44256, 330-723-7780 FE

4/21/2016 4:21:17 PM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS