

Fire Loss Control, Inc.590 Pearl Road
Brunswick, Ohio 44212**Fire Extinguishers****Service History**

Order # 12022

JOB LOCATIONGrandview Pointe Apartments
1939 Green Road
Cleveland Ohio 44121
216-531-3553

Service Date: 3/24/2016

P1: (216)531-3553

P2:

F:

CLIENTFire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212**CONTACT**

Kristen

(216)531-3553

TECHNICIAN

MRO

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 AH861814	LL:4436 garage	5 ABC	2011			AH861814	
2 XN-404151	1:4413 By office	4 ABC	2006		2012	AQ0008220	3/24/2016 10:49:04 AM
3 HH-869310	1:4268 rm 110	5 ABC	1987	2014		AQ0005162	3/24/2016 10:55:21 AM
4 T-479957	1:4288 Mail rm	5 ABC	2010		2012	AQ0008219	3/24/2016 10:52:18 AM
5 JR-988753	1:4286 Electrical rm	5 ABC	1990	2014		AQ0008306	3/24/2016 11:07:51 AM
6 HH-869283	1:4279 rm 118	5 ABC	1987	2014		AQ0005351	3/24/2016 11:10:26 AM
7 AC569217	1:4393 laundry	5 ABC	2010		2016*	AC569217	
8 T-479956	1:Rm 125	5 ABC	2010		2016*	AQ0008222	
9 JR-988686	1:Maint. spare	5 ABC	1990	2014		AQ0008308	3/24/2016 10:04:38 AM
10 JG-809647	1:Maint. spare	5 ABC	1989	2014		AQ0008307	3/24/2016 10:02:25 AM
11 HR-778904	2:spare	5 ABC	1988	2011		AQ0008216	3/24/2016 11:18:32 AM
12 BR655218	2:7930 rm 210	5 ABC	2013			BR655218	
13 SN-482615	2:4273 rm 214	5 ABC	2001	2013		SN-482615	3/24/2016 10:37:03 AM
14 T-479955	2:4274 rm 218	5 ABC	2010		2014	AQ0008217	3/24/2016 10:38:06 AM
15 SN-482620	2:4280 Laundry	5 ABC	2001	2013		SN-482620	
16 SN-482574	2:4271 rm 225	5 ABC	2001	2013		SN-482574	
17 SN-482597	2:4270 Rm 203	5 ABC	2001	2013		SN-482597	
18 RB-849772	3:4278 rm 324	5 ABC	1999	2011		RB-849772	
19 SN-482627	3:4281 rm 311	5 ABC	2001	2013		SN-482627	
20 SU-906748	3:4272 Rm 313	5 ABC	2001	2013		SU-906748	3/24/2016 10:17:04 AM
21 GJ-256881	3 :4265 Rm 314	5 ABC	1986	2011		AQ0008221	
22 AJ479884	3:4392 rm 317	5 ABC	2011			AJ479884	
23 AJ481064	3:4395 laundry	5 ABC	2011			AJ481064	
24 SN-482572	3:4277 RM 303	5 ABC	2001	2013		SN-482572	
25 SN-482593	4:4282 rm 403	5 ABC	2001	2013		SN-482593	
26 T-479958	4:4283 rm 425	5 ABC	2010		2016*	AQ0008213	3/24/2016 10:12:16 AM
27 VX175387	4:4284 Laundry	5 ABC	2003	2016*		AQ0005699	3/24/2016 12:46:04 PM
28 SN-482591	4:5247 rm 417	5 ABC	2001	2012		SN-482591	
29 SN-482577	4:4285 rm 414	5 ABC	2001	2013		SN-482577	

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers

Service History

Order # 12022

JOB LOCATION

Grandview Pointe Apartments
1939 Green Road
Cleveland Ohio 44121
216-531-3553

P1: (216)531-3553
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
30 SN4826%29	4:4275 rm 410	5 ABC	2001	2012		SN-482629	
31 T-484459	4:4287 rm 413	5 ABC	2010			AQ0008215	*** Missing ***
32 D-359583	5:4294 Rm 510	10 ABC	2008		2014	AQ0008211	
33 BX242225	5:Rm 513	5 ABC	2013			BX242225	
34 SN-482592	5:4293 rm 517	5 ABC	2001	2013		SN-482592	
35 BZ310507	5:Rm 514	5 ABC	2013			BZ310507	
36 KC-806337	5:4291 laundry	5 ABC	1991	2011		AQ0008212	
37 SN-482576	5:4290 rm 525	5 ABC	2001	2013		SN-482576	
38 SN-482654	5:4289 rm 503	5 ABC	2001	2013		SN-482654	
39 N912019	6:4391 rm 610	5 ABC	2009		2015	N912019	
40 BZ310506	6:Rm 613	5 ABC	2013			BZ310506	3/24/2016 9:31:18 AM
41 AH861274	6:4437 rm 617	5 ABC	2011			AH861274	
42 HR-779414	6:4269 Rm 614	5 ABC	1988	2011		AQ0008218	
43 HR-779431	6:4298 laundry	5 ABC	1988	2011		AQ0008210	
44 AX83353	6:5246 rm 625	5 ABC	2012			AX83353	
45 SN-482632	6:4264 rm 603	5 ABC	2001	2013		SN-482632	
46 AH642523	Roof:4438 elevator rm	10 ABC	2011			AH642523	
47 SN-482570	spare	5 ABC		2013		SN-482570	3/24/2016 11:17:51 AM
48 NR-678996	2:210	5 ABC	1996	2015		NR-678996	3/24/2016 10:34:49 AM

Extinguisher Work Summary as of 3/24/2016

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	Monthly	Other	Totals
ABC	1	3	38	0	5	0	0	1	48
Totals	1	3	38	0	5	0	0	1	48

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Extinguishers

Service History

Order # 12022

JOB LOCATION

Grandview Pointe Apartments
1939 Green Road
Cleveland Ohio 44121
216-531-3553

P1: (216)531-3553

P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Exhibits

1939 Green Road, Cleveland Ohio 44121, 216-531-3553 FE

3/23/2016 4:05:18 PM

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS