

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems**Service History**

Order # 12238

JOB LOCATION

Symphony at Mentor
8155 Mentor Hills Drive
Mentor Ohio 44060
440-256-8320
Service Date: 4/26/2016

P1: (440)256-8320
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

CONTACT

Steve

TECHNICIAN

MRO

Fire Suppression System

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Ansul

Model: R-102 3 Gallon

Location: Kitchen

Install Date: 1997

Last Service: 4/2016

Duct Size: 2 - 12" X 12"

Nozzle Type: 2 - 2W

Plenum Size: 20" X 12Ft

Nozzle Type: 2 - 1N

Serial #: R-521138

Bar Code: AQ0007135

Timestamp:

Tests/Inspections/Services

Description	Last	Due
Hydro Test	2008	<input type="checkbox"/>
Monthly		<input type="checkbox"/>
Recharge		<input type="checkbox"/>
Semi-Annual	4/2016	<input checked="" type="checkbox"/>
Flush Piping		<input type="checkbox"/>
New		<input type="checkbox"/>

Cylinders

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	3 Gal	Extinguishing Agent	2005	2009			AQ0007136	10/21/2013 12:09:17 PM
2	LT 20	Cartridge	2008	2008				

Replacement Parts

Qty	Description	Part No.	Replaced
3	Fuse Links 360°F K Link	360K-11	10/9/2015
1		R102BDA	4/2014
3	Fuse Links 450°F K Link	450K-11	4/2014
7	Ansul Nozzle Cap	AS77695	4/2014

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems

Service History

Order # 12238

JOB LOCATION

Symphony at Mentor
8155 Mentor Hills Drive
Mentor Ohio 44060
440-256-8320

P1: (440)256-8320
P2:
F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Appliances (Left to Right)

Num	Description	Size	Nozzle(s)
1	Range - 6 Burner	36"	1F, 245
2	Grill - 24"	24"	1N

INSPECTION

I. Fire Suppression Systems

	Yes	No	NA
1. Hood and appliances properly protected?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Was nozzle/appliance alignment correct upon arrival?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
If not was the alignment corrected during inspection?			
3. System cylinder gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Cylinder weight or liquid level OK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Fusible links replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Actuation cartridge weight or gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. Complete fuel shut-down operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Remote pull station accessible and operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. All components clean and free of grease?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Nozzle caps cleaned or replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. System meets manufacturer installation instructions?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. System conduit and piping securely mounted?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. Does system meet UL 300 standard?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14. Employees trained in the proper operation of the system?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15. Audible and/or visual alarms functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. System reset and placed back in service?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. System connected to central station?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18. Class K extinguisher present and functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19. Do hood and duct comply with NFPA #96?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. Company State of Ohio Certification # 53-28-1034	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. State of Ohio Certification Jon LeRoy 54-18-1535	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
22. State of Ohio Certification Marcus R Orahood 54-78-1475	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
23. Complete Hydrostatic Pressure Test Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24. Complete 6 Year Maintenance Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

I state that the information on this form is correct at the time and place of my inspection. And that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection, Inc. / Fire Loss Control, Inc.

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Fire Loss Control, Inc.

590 Pearl Road
Brunswick, Ohio 44212

Fire Suppression Systems

Service History

Order # 12238

JOB LOCATION

Symphony at Mentor
8155 Mentor Hills Drive
Mentor Ohio 44060
440-256-8320

P1: (440)256-8320


P2:

F:

CLIENT

Fire Loss Control, Inc.
590 Pearl Road
Brunswick Ohio 44212

Technician

X 

Marcus R Orahood

4/8/2016

Customer Signature

X 

Steve

4/8/2016

Fire Inspector

X _____

*** End Report: 1 ***

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS