

**Acquire Fire Protection, Inc.**17012 Kinsman Road  
Middlefield, Ohio 44062**Fire Suppression Systems****Service History**

Order # 12284

**JOB LOCATION**Frozen Dee Lite  
16508 Main Market Road  
440-742-0007  
Parkman Ohio 44080  
Service Date: 5/4/2016P1: (440)548-2800  
P2: (440)742-0007  
F:**CLIENT**Bob Kolar  
35609 West Island Drive  
Eastlake Ohio 44095**CONTACT**Bob Kolar  
440-942-3370**TECHNICIAN**

MRO

**Fire Suppression System**

Num: 1

Type: Wet Chemical Extinguishing System

Manufacturer: Amerex

Model: Dual KP 3.75

Location: KITCHEN

Install Date: 2011

Last Service: 5/2016

Duct Size: 2@12" X 18"

Nozzle Type: 2 - 16416

Plenum Size: 18" X 9ft/18" x 12ft

Nozzle Type: 3 - 11982

Serial #: 79257

Bar Code: AQ0007098

Timestamp:

**Tests/Inspections/Services**

Description	Last	Due
Hydro Test	2011	<input type="checkbox"/>
Monthly		<input type="checkbox"/>
Recharge		<input type="checkbox"/>
Semi-Annual	5/2016	<input checked="" type="checkbox"/>
Flush Piping		<input type="checkbox"/>
New		<input type="checkbox"/>

**Cylinders**

Num	Size	Type	Mfg Date	Hydro	6 Year	S/N	Bar Code	Timestamp
1	3.75	Extinguishing Agent	2001	2011		79257	AQ0007099	4/25/2014 10:45:24 AM
2	3.75	Extinguishing Agent	2001	2011		79234	AQ0007100	4/25/2014 10:45:16 AM

**Replacement Parts**

Qty	Description	Part No.	Replaced
4	Fuse Links 360°F K Link	360K-11	4/2014
2	Fuse Links 450°F K Link	450K-11	4/23/2015

**Appliances (Left to Right)**

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Printed on: 5/5/2016 4:02:53 PM

1/3

**Acquire Fire Protection, Inc.**

17012 Kinsman Road  
Middlefield, Ohio 44062

**Fire Suppression Systems**

**Service History**

Order # 12284

**JOB LOCATION**

Frozen Dee Lite  
16508 Main Market Road  
440-742-0007  
Parkman Ohio 44080

**CLIENT**

P1: (440)548-2800  
P2: (440)742-0007  
F:

Bob Kolar  
35609 West Island Drive  
Eastlake Ohio 44095

Num	Description	Size	Nozzle(s)
1	Grill - 48"		11982
2	Fryer - Gas		13729
3	Fryer - Gas		13729
4	Fryer - Gas		13729

**INSPECTION**

**I. Fire Suppression Systems**

	Yes	No	NA
1. Hood and appliances properly protected?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Was nozzle/appliance alignment correct upon arrival?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
If not was the alignment corrected during inspection?			
3. System cylinder gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Cylinder weight or liquid level OK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Fusible links replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Actuation cartridge weight or gauge in operable range?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. Complete fuel shut-down operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Remote pull station accessible and operational?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. All components clean and free of grease?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Nozzle caps cleaned or replaced?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. System meets manufacturer installation instructions?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. System conduit and piping securely mounted?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. Does system meet UL 300 standard?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14. Employees trained in the proper operation of the system?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15. Audible and/or visual alarms functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. System reset and placed back in service?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. System connected to central station?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18. Class K extinguisher present and functional?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19. Do hood and duct comply with NFPA #96?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. Company State of Ohio Certification # 53-28-1034	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. State of Ohio Certification Jon LeRoy 54-18-1535	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
22. State of Ohio Certification Marcus R Orahood 54-78-1475	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
23. Complete Hydrostatic Pressure Test Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24. Complete 6 Year Maintenance Current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

I state that the information on this form is correct at the time and place of my inspection. And that all equipment

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Acquire Fire Protection, Inc.**

17012 Kinsman Road  
Middlefield, Ohio 44062

**Fire Suppression Systems**

**Service History**

Order # 12284

**JOB LOCATION**

Frozen Dee Lite  
16508 Main Market Road  
440-742-0007  
Parkman Ohio 44080

P1: (440)548-2800  
P2: (440)742-0007  
F:

**CLIENT**

Bob Kolar  
35609 West Island Drive  
Eastlake Ohio 44095

**INSPECTION**


**I. Fire Suppression Systems**

Yes No NA

tested at this time was left in operational condition upon completion of this inspection except as noted above.

Acquire Fire Protection, Inc. / Fire Loss Control, Inc.

**Technician**

**X**   
\_\_\_\_\_

**Customer Signature**

**X** \_\_\_\_\_

Marcus R Orahood

5/3/2016

**Fire Inspector**

**X**   
\_\_\_\_\_

Lt. C. Sanders

5/3/2016

\*\*\* End Report: 1 \*\*\*

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS